

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7300-0559:123

Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: Silent Knight Security, 7550 Meridian Cr. #100, Maple Grove, MN 55369
Contact: Brian Foltz (763) 493-6400

DESIGN: Models 5395, 5495 and 5499* Distributed Power Module (Indicating Circuit Expander). Unit is power-limited and consists of an enclosure, printed circuit board, terminal boards, end-of-line resistors and two 12VDC, 7Ah rechargeable batteries. The unit provides up to 4 indicating zones and 1 auxiliary output. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Input: 120 VAC, 2A, 60 hz
Output: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in manner acceptable to the authority having jurisdiction. Unit must be able to provide 24 hour battery back-up as required per code.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as indicating circuit expanders for use with separately listed compatible indicating devices and polarized, 24 VDC, fire alarm control unit. Model 5495 and 5499* can generate a distinctive temporal pattern fire alarm signal as required per NFPA 72, 1999 Edition. If required, models 5395 must be use with fire alarm control unit or indicating signaling devices that can produce the temporal code pattern. Refer to listee's Installation Manual for details.

*Rev. 05-11-01



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 15, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager